



PSB Singapore

CERTIFICATE OF CONFORMITY

No. CLS2 002477 0016 Rev. 00

Initial No. CLS2 17 10 02477 001

Certificate Holder:	Daikin Airconditioning (Singapore) Pte. Ltd. 10 Ang Mo Kio Industrial Park 2 Singapore 569501 SINGAPORE UEN - 1968006072
Product:	Thermal Insulation Materials
Brand Name:	DSP
Model(s):	DSP
Product Details:	Closed Cell Elastomeric Nitrile Rubber Insulation Material Rating: Class 0 Thickness: 25mm Bulk Density: 58kg/m ³ ~ 63kg/m ³
Standard(s):	BS 476-6:1989/A1:2009 BS 476-7:1997
Country of Origin:	Malaysia
Test Report(s):	7191165580-MEC17/1-OKH 7191170337-MEC-YWA 7191201915-MEC19/1-YWA/PIC 7191201915-MEC19/2-YWA/PIC
Valid until:	2027-10-05

Page 1 of 1

Issued on: 2022-09-15

Vice-President (Certification Department)
TÜV SÜD PSB



This Certificate is the property of TÜV SÜD PSB Pte Ltd. Reports listed in this certificate is an integral part of the certificate and should be read in conjunction with it. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking the e-directory: www.tuvsud.com/ps-cert. For more information on TÜV SÜD PSB Pte Ltd product certification: www.tuv-sud-psb.sg