



**VEMAC**  
SERVICES PTE LTD  
PART OF **A-GAS**<sup>®</sup>  
TOGETHER WE CAN

Vemac Services Pte Ltd  
142 Tuas south ave 2  
West point BizHub  
Singapore 637176  
Tel: 6467 3990/4 Fax: 6469 7502  
E-mail: info@vemacservices.com

## Refrigerant Analysis Report

Customer Name	Daikin Airconditioning (Singapore) Pte Ltd	Sample Number	VS1905016
Job Name	DSP R410A Analysis	Customer Sample No.	Nil
Job ID	Nil	Customer PO No.	Nil
Manufacturer	Nil	Collection Date	30/5/2019
Model Number	Nil	Collected By	Senthilkumar
Serial Number	Nil	Receive Date	30/5/2019
Equipment Name	Nil	Analysis Date	30/5/2019
Equipment ID	Nil		

Analysis Items	Sample Results	AHRI 700 Specification	
Water	<10	Max 10 ppm	by weight
High Boiling Residue	<0.01	Max 0.01 %	by weight
Chloride	Pass	Pass	No visible turbidity
Particulates/Solids	Pass	Pass	Visually Clean
Non-Condensable Gas	<1.5	Max 1.5 %	by volume
Acidity	<1	Max 1 ppm	by weight (as HCl)
Volatile Impurities (Total)	<0.5	Max 0.5 %	by weight
Composition: R32	50.5	48.5 – 50.5 %	by weight
R125	49.5	49.5 – 51.5 %	

Remarks: Nil

Recommendation: Nil



Signature of Huang Jianfang

HUANG JIANFANG

APPROVED BY

This report is based on a single sample.

### Terms & Conditions:

1. The Report is prepared for the sole use of the Client and is prepared based upon the sample submitted, the services required by the Client and the conditions under which the Services are performed by Vemac Services.
2. The Report may not be used in any publicity material without the written consent of Vemac Services.
3. Vemac Services shall under no circumstances be liable to the Client or its agents, servants or representatives, in contract, tort (including negligence or breach of statutory duty) or otherwise for any direct or indirect loss or damage suffered by the Client, its agents, servants or representative howsoever arising or whether connected with the Services Provided by Vemac Services herein.