



PSB Singapore

# CERTIFICATE OF CONFORMITY

No. CLS2 17 10 02477 002

Initial No. CLS2 17 10 02477 001

**Certificate Holder:** Daikin Airconditioning (Singapore) Pte. Ltd.  
10 Ang Mo Kio Industrial Park 2  
Singapore 569501  
SINGAPORE

**Product:** Thermal Insulation Materials

**Brand Name:** DSP

**Model(s):** DSP

**Product Details:** Closed Cell Elastomeric Nitrile Rubber Insulation Material  
Density: 63kg/m<sup>3</sup>  
Thickness: 25mm  
(Rating: Class 0)

**Standard(s):** BS 476-6:1989/A1:2009  
BS 476-7:1997

**Test Report(s):** 7191165580-MEC17/1-OKH, 7191170337-MEC17-YWA

**Issued on:** 2017-10-31

**Valid until:** 2022-10-05

Vice-President (Certification Department)  
TÜV SÜD PSB

Page 1 of 1

This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of TÜV SÜD PSB Pte Ltd and shall be returned upon request. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking TÜV SÜD PSB's website at [www.tuv-sud-psb.sg](http://www.tuv-sud-psb.sg)

